

# Somerset/Knob Hill Distribution System

---

Waterworks # 260046137  
System Category – Small Municipal Residential (Stand Alone Distribution System)

## Annual Water Report

Prepared For: The Township of Ramara

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup>, 2023

Issued: February 27, 2024

Revision: 0

Operating Authority:



This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22

## Table of Contents

Annual Water Report .....	1
Report Availability .....	1
Compliance Report Card .....	1
System Process Description .....	1
Raw Source .....	1
Distribution System.....	1, 2
Treatment Chemicals used during the reporting year: .....	2
Summary of Non-Compliance.....	2
Adverse Water Quality Incidents.....	2
Non-Compliance .....	2
Non-Compliance Identified in a Ministry Inspection: .....	2
Flows .....	2
Regulatory Sample Results Summary .....	3
Microbiological Testing .....	3
Operational Testing .....	3
Inorganic Parameters .....	3
Schedule 15 Sampling: .....	3
Organic Parameters.....	4
Additional Legislated Samples.....	4
Inorganic or Organic Parameter Exceedances .....	4
Major Maintenance Summary .....	4

## Report Availability

This system does not serve more than 10,000 residence and the annual reports will be available to residents at the Township Of Ramara Administration Office and on the Township's website at [www.ramara.ca](http://www.ramara.ca). Notification that reports are available free of charge will be made on the Township of Ramara website. The Township of Ramara Administration Office is located at 2297 Highway 12, Brechin, ON L0K 1B0.

## Compliance Report Card

**Drinking Water System Number:** 260046137

**Drinking Water System Name:** Somerset/ Knob Hill Water Distribution System

**Drinking Water System Owner:** Township of Ramara

**Drinking Water System Category:** Small Municipal Residential (Stand Alone Distribution System)

**Period Being Reported:** January 1, 2023 - December 31, 2023

	# of Events	Date	Details
<b>Health &amp; Safety</b>			
Number of Incidents	0		
<b>Drinking Water</b>			
MECP Inspections	1	June 27, 2023	Announced – Focused - Drinking Water Inspection – Final Inspection Rating of 100%
AWQI's	0		
Number of Non-Compliances	0		
Number of Boil Water Advisories	0		

## System Process Description

### Raw Source

The distribution system receives treated water from the Township of Severn's Washago Water Treatment Plant (DWS No. 220005161) which receives its raw water from Lake Couchiching. The Township of Severn's Washago Water Treatment Plant is a Large Municipal Residential drinking water system that provides disinfection with sodium hypochlorite, coagulation and flocculation with alum and a cationic polymer and multi-media filtration.

### Distribution System

The distribution system consists of approximately 700m of 50mm diameter watermain, including a watermain that conveys treated water across the Severn River. There are three sample stations installed in the distribution system and one blow-off.

**Treatment Chemicals used during the reporting year:**

Chemical Name	Use	Supplier
No chemicals are used.		

**Summary of Non-Compliance**

**Adverse Water Quality Incidents**

Date	AWQI #	Location	Problem	Details	Legislation	Corrective Action
No adverse water quality events during the reporting period.						

**Non-Compliance**

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e. date(s))	Corrective Action	Status
There were no non-compliance issues reported during the reporting period.				

**Non-Compliance Identified in a Ministry Inspection:**

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e. date(s))	Corrective Action	Status
There were no non-compliances identified in a Ministry Inspection during this period.				

**Flows**

**Treated Water Flows**

Daily water use is monitored by a magnetic flow meter owned and operated by the Township of Severn. Flow meter readings are collected by operations staff throughout the year to monitor water consumption. Based on the readings collected in 2023 the estimated average daily flow is: 4.27 m<sup>3</sup>/day. The estimated total annual flows for 2023 is: 1549.65 m<sup>3</sup>. Based on 20 connected lots, with an estimated population of 52 residents (based on the average population of 2.6 people per dwelling). The estimated per capita average water consumption is: 82L/p/day.

## Regulatory Sample Results Summary

### Microbiological Testing

	No. of Samples Collected	Range of E. Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min	Max	Min	Max	Min	Max
Raw Water	No Raw Water Samples Required.						
Treated	No Treated Water Samples Required.						
Distribution	26	0	0	0	0	0	5

### Operational Testing

	No. of Samples Collected	Range of Results	
		Minimum	Maximum
Distribution Water Chlorine	105	0.97	1.79
Fluoride (If the DWS provides fluoridation)	N/A	N/A	N/A

**Note:** Record the unit of measure if it is **not** milligrams per litre.

### Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every 5 years. Nitrate and Nitrite are tested quarterly and the metals are tested annually as required under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Method Detection Limit

Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
No requirement to sample inorganics in the system.					

### Schedule 15 Sampling:

The Schedule 15 Sampling is required under O. Reg. 170/03. This system is under reduced sampling. No plumbing samples are collected.

Distribution System	Number of Samples	Range of Results Minimum	Range of Results Maximum	MAC (ug/L)	Number of Exceedances
Alkalinity (mg/L)	2	85	112	N/A	N/A
pH	2	7.9	8.2	N/A	N/A
Lead (ug/l)	0	-	-	10	0

**Note:** Lead is only required to be sampled every 3 years and was last done in 2022.

**Organic Parameters**

These parameters are tested as a requirement under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
<b>Distribution Water</b>					
Trihalomethane: Total (ug/L) Annual Average - DW	2023	52.25	100	No	Yes
HAA Total (ug/L) Annual Average - DW	2023	30.45	80	No	No

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

**Additional Legislated Samples**

Municipal Drinking Water License	Parameter	Date Sampled	Result	Unit of Measure
No additional legislated samples.				

**Inorganic or Organic Parameter Exceedances**

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THM	52.25	ug/L	2023

**Major Maintenance Summary incurred to install, repair or replace required equipment**

Item #	Description
1	Sample station replaced