

WD-107 DISTRIBUTION SYSTEM WATERWORKS # 260046137

SMALL MUNICIPAL RESIDENTIAL (STAND ALONE DISTRIBUTION SYSTEM)

ANNUAL WATER REPORT

PREPARED FOR
The Township of Ramara

SUBMITTED BY
Ontario Clean Water Agency
2115 Highway 12, Brechin, ON L0K 1B0

Reporting Period: January 1 – December 31, 2025

Issued: February 13, 2026

Revision: 0

Operating Authority: Ontario Clean Water Agency (OCWA)

This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22

Table of Contents

1. Report Availability	1
2. Compliance Report Card.....	1
3. System Process Description.....	1
Raw Source	1
Distribution System	2
4. Summary of Non-Compliance.....	2
Adverse Water Quality Incidents.....	2
Non-Compliance	2
Non-Compliance Identified in a Ministry of the Environment Conservation and Parks Inspection... 2	
Flows.....	2
Treated Water Flows	2
5. Regulatory Sample Results Summary	3
Microbiological Testing.....	3
Operational Testing	3
Inorganic Parameters.....	3
Schedule 15 Sampling:.....	3
Organic Parameters	4
Additional Legislated Samples.....	4
6. Major Maintenance Summary incurred to install, repair or replace required equipment	5

1. Report Availability

This system does not serve more than 10,000 residence and the annual reports will be available to residents at the Township of Ramara Administration Office and on the Township’s website at www.ramara.ca. Notification that reports are available free of charge will be made on the Township of Ramara website. The Township of Ramara Administration Office is located at 2297 Highway 12, Brechin, ON L0K 1B0.

2. Compliance Report Card

Drinking Water System Number: 260046137

Drinking Water System Name: WD-107 (Somerset/ Knob Hill Water Distribution System)

Drinking Water System Owner: Township of Ramara

Drinking Water System Category: Small Municipal Residential (Stand Alone Distribution System)

Period Being Reported: January 1, 2025 - December 31, 2025

Health & Safety	Number of Events	Date	Details
Number of Incidents	0	N/A	N/A

Drinking Water	Number of Events	Date	Details
Ministry of the Environment Conservation and Parks (MECP) Inspections	1	January 20, 2026	Announced Drinking Water Inspection for 2025 cycle. Final inspection rating not received at time of report.
Adverse Water Quality Incidents (AWQI)	0	N/A	N/A
Number of Non-Compliances	0	N/A	N/A
Number of Boil Water Advisories	0	N/A	N/A

3. System Process Description

Raw Source

The distribution system receives treated water from the Township of Severn’s Washago Water Treatment Plant (DWS No. 220005161) which receives its raw water from Lake Couchiching. The Township of Severn’s Washago Water Treatment Plant is a Large Municipal Residential drinking water system that provides disinfection with sodium hypochlorite, coagulation and flocculation with alum and a cationic polymer and multi-media filtration.

Distribution System

The distribution system consists of approximately 700m of 50mm diameter watermain, including a watermain that conveys treated water across the Severn River. There are three sample stations installed in the distribution system and one blow-off.

Treatment Chemicals used during the reporting year:

Chemical Name	Use	Supplier
No chemicals are used.		

4. Summary of Non-Compliance

Adverse Water Quality Incidents

Date	AWQI #	Location	Details	Legislation	Corrective Action
No adverse water quality events during the reporting period.					

Non-Compliance

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e., date(s))	Corrective Action	Status
There were no non-compliance issues reported during the reporting period.				

Non-Compliance Identified in a Ministry of the Environment Conservation and Parks Inspection:

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e., date(s))	Corrective Action	Status
There were no non-compliances identified in a Ministry of the Environment Conservation and Parks Inspection during this period.				

Flows

Treated Water Flows

Daily water use is monitored by a magnetic flow meter owned and operated by the Township of Severn. Flow meter readings are collected by operations staff throughout the year to monitor water consumption. Based on the readings collected in 2025 the estimated average daily flow is: 4.29 m³/day. The estimated total annual flows for 2025 is: 1568.81 m³. Based on 20 connected lots, with an estimated population of 52 residents (based on the average population of 2.6 people per dwelling). The estimated per capita average water consumption is: 82.5 L/p/day.

5. Regulatory Sample Results Summary

Microbiological Testing

	Number of Samples Collected	Range of E. Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min	Max	Min	Max	Min	Max
Raw Water	No Raw Water Samples Required.						
Treated	No Treated Water Samples Required.						
Distribution	27	0	0	0	0	0	1

Operational Testing

	Number of Samples Collected	Range of Results	
		Minimum	Maximum
Distribution Water Chlorine	106	0.89	1.87
Fluoride (If the DWS provides fluoridation)	N/A	N/A	N/A

Note: Record the unit of measure if it is not milligrams per litre.

Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every 5 years. Nitrate and Nitrite are tested quarterly and the metals are tested annually as required under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Method Detection Limit

Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MDL	Exceedances	
				MAC	1/2 MAC
No requirement to sample inorganics in the system.					

Schedule 15 Sampling:

The Schedule 15 Sampling is required under O. Reg. 170/03. This system is under reduced sampling. No plumbing samples are collected.

Distribution System	Number of Samples	Range of Results Minimum	Range of Results Maximum	MAC (ug/L)	Number of Exceedances
Alkalinity (mg/L)	2	85	102	N/A	N/A
pH	2	7.6	7.8	N/A	N/A
Lead (ug/l)	0	0.05	0.09	10	0

Note: Lead is required to be sampled every 3 years and is scheduled to be sampled in 2028.

Organic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

Distribution Water	Sample Date (yyyy/mm/dd)	Sample Result	MDL	Exceedances	
				MAC	1/2 MAC
Trihalomethane: Total (ug/L) Running Annual Average – DW	2025	43.75	100	No	No
Haloacetic Acids Total (ug/L) Running Annual Average - DW	2025	26.35	80	No	No

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

Additional Legislated Samples

Municipal Drinking Water License	Parameter	Date Sampled	Result	Unit of Measure
No additional legislated samples.				

Inorganic or Organic Parameter Exceedances

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
No parameters exceeded half the standard.			

6. Major Maintenance Summary incurred to install, repair or replace required equipment

Item #	Description
1	No major maintenance activities were completed during this period. Only routine maintenance was performed to ensure equipment remains in safe and reliable operating condition.